

Certification No	Certifier	Applicant : ADM	Equipment Class	Description
: ESV210348	: ESV	Instrument Engineering	: Level 3 - Power Supply or Charger	: Independent LED Driver
Certified Date	Expiry Date	Standard: 61347.1:2016+A1 & AS 61347.2.13:2018		
: 10/29/2021	: 10/28/2026			
Certification Conditions: Non-IC independent controlgear for use with LED lighting equipment. Not suitable for residential use with recessed luminaires.				

Profiles

Model	Trade Name	Profile	Inputs	Outputs	Comments
SLD-50-12	MEAN WELL		110-240V~, 0.6A, 50/60Hz	12Vd.c., Max. 13Vd.c., 4.2A, 50.4W	Class II, ta: 50oC, tc: 90oC, Non IC
SLD-50-24	MEAN WELL		110-240V~, 0.6A, 50/60Hz	24Vd.c., Max. 25Vd.c., 2.1A, 50.4W	Class II, ta: 50oC, tc: 90oC, Non IC
SLD-50-56	MEAN WELL		110-240V~, 0.6A, 50/60Hz	30-56Vd.c., Max. 60Vd.c., 0.9-1.4A, 50.4W	Class II, ta: 50oC, tc: 90oC, Non IC

Version 1.4 Last Updated: 3 July, 2009

© Copyright State of Victoria | [Disclaimer](#) | [Privacy Statement](#) | [State Government of Victoria Home](#) |