

Certification No	Certifier	Applicant : ADM	Equipment Class	Description
: ESV210356	: ESV	Instrument Engineering	: Level 3 - Power Supply or Charger	: Independent LED Driver
Certified Date : 11/12/2021	Expiry Date : 11/12/2026	Standard : 61347.1:2016 +A1 and AS 61347.2.13:2018		
Certification Conditions : Non-IC independent controlgear for use with LED lighting equipment. Not suitable for residential use with recessed luminaires.				

Profiles

Model	Trade Name	Profile	Inputs	Outputs	Comments
SLD-80-12	MEAN WELL		110-240V~, 0.85A, 50/60Hz	12Vd.c., Max. 13Vd.c., 6.6A, 79.2W	Class II, ta: 50oC, tc: 90oC, Non IC
SLD-80-24	MEAN WELL		110-240V~, 0.85A, 50/60Hz	24Vd.c., Max. 25Vd.c., 3.3A, 79.2W	Class II, ta: 50oC, tc: 90oC, Non IC
SLD-80-56	MEAN WELL		110-240V~, 0.85A, 50/60Hz	30-56Vd.c., Max. 60Vd.c., 1.4-2.1A, 78.4W	Class II, ta: 50oC, tc: 90oC, Non IC

Version 1.4 Last Updated: 3 July, 2009

© Copyright State of Victoria | [Disclaimer](#) | [Privacy Statement](#) | [State Government of Victoria Home](#) |