

Back

?

| | | | | |
|---|--------------------|------------------------------------|---|--------------------|
| Certification No | Certifier | Applicant | Equipment Class : Level 3 | Description |
| : ESV180528 | : ESV | : ADM Instrument Engineering | - Power Supply or Charger - Power Supply | : LED Driver |
| Certified Date | Expiry Date | Standard | 61347.1:2016 & AS/NZS IEC 61347.2.13:2013 | |
| : 28/05/2019 | : 19/10/2023 | | | |
| Certification Conditions: Alternate approval marking ESV130642 | | | | |

Profiles

| Model | Trade Name | Profile | | | |
|----------|------------|-----------------|-----------------------------|----------------|---|
| LCM-40KN | Meanwell | Inputs | 200-240V, 0.27A, 50/60Hz | Outputs | 40-100V max., 1.05A- 0.35A, Max. 42W |
| | | Comments | | | |
| LCM-60KN | Meanwell | Inputs | 200-240V, 0.37A, 50/60Hz | Outputs | 42-90V max., 1.4A- 0.5A, Max. 60.3W |
| | | Comments | | | |

Version 1.4 Last Updated: 3 July, 2009

© Copyright State of Victoria | [Disclaimer](#) | [Privacy Statement](#) | [State Government of Victoria Home](#) |