

[Back](#)[?](#)

Certification	Certifier	Applicant	Equipment	Description
No : ESV150413	ESV	: ADM Instrument Engineering	Class : Level 3 - Power Supply or Charger	: Independen_LED_control_gear_ _constant_voltage_type
Certified Date: 2/25/2019	Expiry Date : 7/3/2020	Standard:	IEC 61347.2.13:2013	
Certification Conditions: Intended for fixed wiring or built-in.				

Profiles

Model	Trade Name	Profile	Inputs	Outputs
PWM-60-12DA	Meanwell		100-240V~, 0.8A, 50/60Hz	12Vdc, 5A, 60W
		Comments	Class II, IP67, ta: 50C, tc: 85C	
PWM-60-24DA	Meanwell		100-240~, 0.8A, 50/60Hz	24Vdc , 2.5A, 60W
		Comments	Class II, IP67, ta: 50C, tc: 85C	

Version 1.4 Last Updated: 3 July, 2009

© Copyright State of Victoria | [Disclaimer](#) | [Privacy Statement](#) | [State Government of Victoria Home](#) |