

Certification No : ESV180499	Certifier : ESV	Applicant : ADM Instrument Engineering	Equipment Class : Level 3 - Power Supply or Charger - Power Supply	Description : LED Driver
Certified Date: 7/15/2020	Expiry Date: 10/5/2023	Standard: 61347.1:2016 & 61347.2.13:2013		
Certification Conditions: Alternate approval marking ESV130642				

Profiles

Model	Trade Name	Profile		Outputs	
LCM-25KN	MEAN WELL	Inputs	200-240VAC, 0.2A, 50/60Hz	Outputs	24-54VDC, 1.05-0.35A, 25.2W max
		Comments	Class II, ta:40-50oC, tc:85oC		

Version 1.4 Last Updated: 3 July, 2009

© Copyright State of Victoria | [Disclaimer](#) | [Privacy Statement](#) | [State Government of Victoria Home](#) |