



## Declaration of conformity

For the following equipment :

**Product Name: Surge Protection Device**

**Model Designation: SPD-20-240P**

**Identification:**

|   |                |
|---|----------------|
| Max. Continuous operating voltage(Uc)       | AC300V         |
| Voltage protection Level(Up)                | 1500V          |
| Test Class                                  | II             |
| Nominal Discharge Current(In) :             | 5KA            |
| Max. Discharge Current(I <sub>max</sub> ) : | 20KA           |
| Protection Degree :                         | IP67           |
| Location Category :                         | Indoor         |
| Temperature Range :                         | -40°C to +70°C |

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

**RoHS Directive (2011/65/EU)**

**Low Voltage Directive (2014/35/EU) :**

EN 61643-11:2012

TUV certificate No: R 50320011

**Note:**

This Declaration is effective from serial number HB6xxxxxxx

Person responsible for marking this declaration :

**MEAN WELL (Guangzhou) Electronics Co., Ltd.**

(Manufacturer Name)

**2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District, Guangzhou, China**

(Manufacturer Address)

Howay\_Lin/ Engineering Manager :

(Name / Position)

*Howay Lin*  
(Signature)

Frank\_Peng/ RD Manager :

(Name / Position)

*Frank Peng*  
(Signature)

**GuangZhou**

(Place)

**Apr. 20, 2016**

(Date)